

PUZ-WM50VHA

CIBSE TM65 Embodied Carbon Mid-level Calculation Including Operational Carbon Benchmark Estimate







Operational carbon data for heating requirements, according to heat pump ErP fiche at medium temperature (55°C), average climate conditions and equivalent boiler heat output. Gas boiler assumptions: embodied carbon of 300kg CO,e, efficiency of 93%, service life of 15 years.

Carbon factors sources:

Electrical grid according to Greenbook forecast for residential use. (source: gov.uk, IAG spreadsheet toolkit for valuing changes in greenhouse gas emissions, sheet conversion CO₂). Gas network according to SAP 10.1 carbon emissions factor (source: BRE Group, SAP-10.1-01-10-2019, Page 171).

PUZ-WM50VHA - Product Inform	ation					
Type of product	A2W Heat pump					
Capacity of equipment (kW)	5					
Product weight (kg)	69					
Material breakdown for at least 95% of the product weight? (Y/N)	Y					
Service life of the product (years)	15					
Type of refrigerant	R32					
Refrigerant GWP	675					
Refrigerant charge (kg)	2.0					
Energy consumption of the factory per unit of product (kWh)	66.66					
Location of manufacture	UK					
Product Complexity	Category 3: High					





PUZ-WM50VHA

CIBSE TM65 Embodied Carbon Mid-level Calculation Including Operational Carbon Benchmark Estimate



Embodied Carbon Results Breakdown (kg CO_2e)							
A1: Material extraction	459						
A2: Transport	55						
A3: Manufacturing	77						
A4: Transport to Site	0						
B1: Use	405						
B3: Repair	61						
C1: Deconstruction	14						
C2: Transport	1						
C3: Waste Processing	19						
C4: Disposal	0						
Embodied Carbon Results - without Refrigerant Leakage (kg $\rm CO_2e$)							
A1-C4 (excluding B1,C1)	674						
A1-C4 with Buffer Factor (excluding B1, C1)	876						
Embodied Carbon Result - Refrigerant Leakage Only (kg $\rm CO_2e$)							
B1 (Refrigerant leakage during use) + C1 (Refrigerant leakage end of life)	419						
Assumptions							
A1: Material carbon coefficient source	TM65 Table 2.1 & The ICE Database						
B1: Refrigerant annual leakage rate (%)	2 (TM65 Assumption)						

B3: Materials replaced as part of repair (%) C4: Percentage of product going to landfill (%)

C1: Refrigerant end of life recovery rate (%)

Operational Carbon																
Year ^{*1}	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10	Y11	Y12	Y13	Y14	Y15	Cumulative Total
Heat Pump (kg CO ₂ e)	323	337	314	317	297	317	300	277	249	220	185	171	149	123	123	3,704

Note: kg CO₂e calculation results are rounded to the nearest whole number. *1 Y1 = starting from 2022



Telephone: 01707 282880 email: heating@meuk.mee.com ecodan.co.uk

😏 @Ecodanheating 📊 Mitsubishi Electric Heating UK 👖 @MitsubishiElectricHeatingUK 👩 mitsubishi_electric_heating_uk 🕞 Mitsubishi Electric Heating UK 🔢 🚺 thehub.mitsubishielectric.co.uk

UNITED KINGDOM Mitsubishi Electric Europe Living Environment Systems Division, Travellers Lane, Hatfield, Hertfordshire, AL10 8XB, England. Telephone: 01707 282880 Fax: 01707 278881 IRELAND Mitsubishi Electric Europe, Westgate Business Park, Ballymount, Dublin 24, Ireland. Telephone: (01) 419 8800 Fax: (01) 419 8890 International code: (003531)

Country of origin: United Kingdom - Japan - Thailand - Malaysia. @Mitsubishi Electric Europe 2021. Mitsubishi and Mitsubishi Electric are trademarks of Mitsubishi Electric Europe B.V. The company reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement. Mitsubishi Electric is constantly developing and improving its products. All descriptions, illustrations, drawings and specifications in this publication present only general particulars and shall not form part of any contract. All goods are supplied subject to the Company's General Conditions of Sale, a copy of which is available on request. Third-party product and hand names may be trademarks or registered trademarks of their respective owners.

Note: The fuse rating is for updance only. Please refer to the relevant databook for detailed specification. It is the responsibility of a qualified electrician/electrical engineer to select the correct cable size and fuse rating based on current regulation and site specific conditions. Mitsubishi Electric's air conditioning equipment and heat pump systems contain a fluorinated greenhouse gas, R410A (GWP-2088), R32 (GWP-675), R407C (GWP:1774), R134a (GWP-1430), R513A (GWP-631), R454B (GWP-469), R1234c (GWP-7) or R1234y (GWP-7) or R1234y (GWP-1300).

Effective as of November 2021





99 (TM65 Assumption)

10 (TM65 Assumption)

30 (TM65 Assumption)