

Air Conditioning

Statement of
eligibility for ECA

Making a
World of
Difference

Mitsubishi Electric UK confirms the following combinations meet or exceed the standards set out in
The Energy Technology List: Air Source Heat Pump Split and Multi-Split systems

≤12kW - EN14825 Minimum criteria SEER ≥ 6.10; SCOP ≥ 4.00					
Indoor	Outdoor	Cooling Capacity	Heating Capacity	SCOP	SEER
MSZ-SF25VE2	MUZ-SF25VE	2.5	3.2	4.4	7.6
MSZ-SF35VE2	MUZ-SF35VE	3.5	4.0	4.4	7.2
MSZ-SF50VE2	MUZ-SF50VE	5.0	5.8	4.4	7.2
MSZ-GF60VE	MUZ-GF60VE	6.0	6.8	4.3	6.8
MSZ-GF71VE	MUZ-GF71VE	7.1	8.1	4.2	6.8
MSZ-FH25VE	MUZ-FH25VE	2.5	3.2	5.1	9.1
MSZ-FH35VE	MUZ-FH35VE	3.5	4.0	5.1	8.9
MSZ-EF25VE2B	MUZ-EF25VE	2.5	3.2	4.7	8.5
MSZ-EF25VE2S	MUZ-EF25VE	2.5	3.2	4.7	8.5
MSZ-EF25VE2W	MUZ-EF25VE	2.5	3.2	4.7	8.5
MSZ-EF35VE2B	MUZ-EF35VE	3.5	4.0	4.6	8.5
MSZ-EF35VE2S	MUZ-EF35VE	3.5	4.0	4.6	8.5
MSZ-EF35VE2W	MUZ-EF35VE	3.5	4.0	4.6	8.5
MSZ-EF50VE2B	MUZ-EF50VE	5.0	5.8	4.5	7.2
MSZ-EF50VE2S	MUZ-EF50VE	5.0	5.8	4.5	7.2
MSZ-EF50VE2W	MUZ-EF50VE	5.0	5.8	4.5	7.2
MFZ-KJ25VE	MUFZ-KJ25VE	2.5	3.4	4.5	8.5
MFZ-KJ35VE	MUFZ-KJ35VE	3.5	4.3	4.4	7.8
MFZ-KJ50VE	MUFZ-KJ50VE	5.0	6.0	4.3	6.5
SLZ-KF25VA	SUZ-KA25VA5	2.6	3.2	4.3	6.3
SLZ-KF35VA	SUZ-KA35VA5	3.5	4.0	4.3	6.5
SLZ-KF50VA	SUZ-KA50VA5	4.6	5.0	4.3	6.3
SLZ-KF60VA	SUZ-KA60VA5	5.6	6.4	4.1	6.2
PLA-ZRP35BA	PUHZ-ZRP35VKA	3.6	4.1	4.6	6.8
PLA-ZRP50BA	PUHZ-ZRP50VKA	5.0	6.0	4.6	6.4
PLA-ZRP60BA	PUHZ-ZRP60VKA	6.1	7.0	4.2	6.1
PLA-ZRP71BA	PUHZ-ZRP71VHA	7.1	8.0	4.5	6.7
PLA-ZRP100BA	PUHZ-ZRP100VKA2	10.0	11.2	4.8	6.9
PLA-ZRP100BA	PUHZ-ZRP100YKA2	10.0	11.2	4.8	6.8
PKA-RP60KAL	PUHZ-ZRP60VHA	6.1	7.0	4.2	6.3
PKA-RP71KAL	PUHZ-ZRP71VHA	7.1	8.0	4.3	6.5
PSA-RP71KA	PUHZ-ZRP71VHA	7.1	8.0	4.0	6.3
PKA-RP100KAL	PUHZ-ZRP100VKA2	10.0	11.2	4.1	6.1
PCA-RP60KAQ	PUHZ-ZRP60VKA	6.0	7.0	4.3	6.2
PCA-RP71KAQ	PUHZ-ZRP71VKA	7.1	8.0	4.3	6.6

>12kW - EN14511 Minimum criteria EER > 3.20; COP > 3.70					
Indoor	Outdoor	Cooling Capacity	Heating Capacity	COP	EER
PLA-ZRP125BA	PUHZ-ZRP125VKA2	12.5	14.0	3.81	3.23
PLA-ZRP125BA	PUHZ-ZRP125YKA2	12.5	14.0	3.81	3.23
PEAD-RP125JAQ	PUHZ-ZRP125VKA2	12.5	14.0	3.99	3.24
PEAD-RP125JAQ	PUHZ-ZRP125YKA2	12.5	14.0	3.99	3.24

Air Source: Split and Multi-split (incl VRF) products became an "UNLISTED" technology on 7TH AUGUST 2014. For products purchased from this date onwards, purchasers need to obtain a statement from Mitsubishi Electric to confirm that the product meets the eligibility criteria in force at the time of purchase. This statement should then be used as the supporting evidence for the purchaser's ECA claim. Note that previously listed products will show on the ETL as removed on 7TH August. This does not necessarily mean that the products are no longer eligible for ECA claims – just that they have all been removed from the Energy Technology Product List, because the sub-technology category is now unlisted. Purchasers may continue to claim ECAs if the product meets the criteria detailed on the Energy Technology Criteria List, and is certified as such by Mitsubishi Electric. For enquiries contact ECAQuestions@carbontrust.co.uk

For more details of the ETL and ECA scheme, please visit <https://etl.decc.gov.uk/>

Disclaimer: HM Revenue and Customs has the final say on all claims for Enhanced Capital Allowance. The information provided should be used as a guide only



Telephone: 01707 282880

email: air.conditioning@meuk.mee.com web: airconditioning.mitsubishielectric.co.uk

