

**MITSUBISHI ELECTRIC**  
**AIR CONDITIONING SYSTEMS EUROPE LTD.**  
 NETTLEHILL ROAD  
 HOUSTOUN INDUSTRIAL ESTATE  
 LIVINGSTON, EH54 5EQ, U.K.  
 Telephone: +44 (0)1506 445500  
 Fax: +44 (0)1506 445511

**UK DECLARATION OF CONFORMITY**

**This declaration of conformity is issued under the sole responsibility of the manufacturer.**

**We** MITSUBISHI ELECTRIC AIR CONDITIONING SYSTEMS EUROPE LTD.

NETTLEHILL ROAD HOUSTOUN INDUSTRIAL ESTATE LIVINGSTON EH54 5EQ SCOTLAND,  
 UNITED KINGDOM

**are the manufacturer of below models and hereby declares under its sole responsibility that the AIR CONDITIONERS and HEAT PUMPS described below for use in residential, commercial and light-industrial environments:**

MITSUBISHI ELECTRIC, PUZ-ZM60VHA2, PUZ-ZM71VHA2

**comply with the provisions of the following Legislation, the Designated Standards and the specifications.:**


Legislation	Designated Standards / Specifications
The Electrical Equipment (Safety) Regulations 2016	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012, EN 62233: 2008, IEC 60335-1:2010, IEC 60335-2-40:2013
The Supply of Machinery (Safety) Regulations 2008	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012
The Electromagnetic Compatibility Regulations 2016	EN 55014-1: 2006 / A1:2009 / A2:2011, EN 61000-3-2: 2014, EN 61000-3-3: 2013, EN 55014-2: 1997 / A1: 2001 / A2: 2008 (Category IV)
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012	EN IEC 63000: 2018
The Ecodesign for Energy-Related Products Regulations 2010*	EN 14511-3:2013, EN 14825:2016

\*Please refer to <http://uk.erp.mitsubishielectric.eu/erp/territory> for more information.

\*\*Information of The Pressure Equipment (Safety) Regulations 2016

Pressure Component	Accumulator	Category II
	Pressure Switch	Category IV
Applied conformity assessment procedure:	Internal manufacturing checks with monitoring of the final assessment (module D1)	
The monitoring is performed by the Notified Body:	BSI Group The Netherlands B.V. Say Building, John M. Keynesplein 9, 1066 EP Amsterdam, Netherlands	

**Issued date:** 30 September, 2022



Atsushi EDAYOSHI

Manager, Quality Assurance Department

UNITED KINGDOM

**Revised date:** ---