

MITSUBISHI ELECTRIC
AIR CONDITIONING SYSTEMS EUROPE LTD.
 NETTLEHILL ROAD
 HOUSTOUN INDUSTRIAL ESTATE
 LIVINGSTON, EH54 5EQ, U.K.
 Telephone: +44 (0)1506 445500
 Fax: +44 (0)1506 445511

UK DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer.

We MITSUBISHI ELECTRIC AIR CONDITIONING SYSTEMS EUROPE LTD.

NETTLEHILL ROAD HOUSTOUN INDUSTRIAL ESTATE LIVINGSTON EH54 5EQ SCOTLAND,
 UNITED KINGDOM

are the manufacturer of below models and hereby declares under its sole responsibility that the AIR CONDITIONERS and HEAT PUMPS described below for use in residential, commercial and light-industrial environments:

MITSUBISHI ELECTRIC, PUZ-ZM100YKA2

comply with the provisions of the following Legislation, the Designated Standards and the specifications.:

Legislation	Designated Standards / Specifications
The Electrical Equipment (Safety) Regulations 2016	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012, EN 62233: 2008, IEC 60335-1:2010, IEC 60335-2-40:2013
The Supply of Machinery (Safety) Regulations 2008	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012
The Electromagnetic Compatibility Regulations 2016	EN 55014-1: 2006 / A1:2009 / A2:2011, EN 61000-3-2: 2014, EN 61000-3-3: 2013, EN 55014-2: 1997 / A1: 2001 / A2: 2008 (Category IV)
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012	EN IEC 63000: 2018
The Ecodesign for Energy-Related Products Regulations 2010*	EN 12102-1:2017, EN 14511-2:2013, EN 14511-3:2013, EN 14825:2016

*Please refer to <http://uk.erp.mitsubishielectric.eu/erp/territory> for more information.

**Information of The Pressure Equipment (Safety) Regulations2016

Pressure Component	Accumulator	Category II
	Compressor	Category II
	Pressure Switch	Category IV
Applied conformity assessment procedure:	Internal manufacturing checks with monitoring of the final assessment (module D1)	
The monitoring is performed by the Notified Body:	BSI Group The Netherlands B.V. Say Building, John M. Keynesplein 9, 1066 EP Amsterdam, Netherlands	

Issued date: 30 September, 2022



 Atsushi EDAYOSHI

Manager, Quality Assurance Department

UNITED KINGDOM

Revised date: ---